Lead in Water Test Results Summary: Sherwood Charter School

Notes:

- **The lead in water Action Level is 15 parts per billion (ppb).**
  Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "**ND**" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
[enter description]	*[enter ID #]*	*[enter date]*	*[enter result]*	*[autofill]*	*[enter date]*	*[enter result]*	*[autofill]*
Downstairs Fountain Bottle Filler	22440600-009WB	10/20/23	ND	Non-Detect			
Downstairs Fountain Water Spout	22440600-010DW	11/07/23	ND	Non-Detect			
Downstairs Boys Restroom	22440600-001BF	10/20/23	ND	Non-Detect			
Downstairs Girls Restroom	22440600-005BF	10/20/23	1	Low	1/31/2025	4.4	Low
Office Water Cooler	22440600-014WC	10/20/23	ND	Non-Detect			
Upstairs Adult Bathroom Left	22440600-003BF	10/20/23	ND	Non-Detect			
Upstairs Adult Bathroom Right	22440600-004BF	10/20/23	ND	Non-Detect			
Upstairs Fountain	22440600-011DW	10/20/23	ND	Non-Detect			
Upstairs Boys Restroom	22440600-002BF	10/20/23	ND	Non-Detect			
Upstairs Girls Restroom	22440600-006BF	10/20/23	10	**High**	1/31/2025	3	Low
Kitchen Sink Left	22440600-012KF	10/20/23	ND	Non-Detect			
Kitchen Sink Right	22440600-013KF	10/20/23	ND	Non-Detect			
Classroom 4 Science Sink Left	22440601-001CF	10/20/23	ND	Non-Detect			
Classroom 4 Science Sink Right Pull Out	22440601-002CF	10/20/23	ND	Non-Detect			
Classroom 4 Science Water Fountain	22440601-003DW	10/20/23	ND	Non-Detect			
Classroom 4 Science Bathroom Faucet	22440601-004BF	10/20/23	ND	Non-Detect	11/12/2023	ND	Non-Detect
Classroom 5 Art Bathroom Faucet	22440601-005BF	10/20/23	ND	Non-Detect			
Classroom 5 Art Sink Left Pull Out	22440601-006CF	10/20/23	ND	Non-Detect			
Classroom 5 Art Sink Right	22440601-007CF	10/20/23	ND	Non-Detect			
Classroom 5 Art Water Faucet	22440601-008DW	10/20/23	ND	Non-Detect			
Classroom 6 Humanities Bathroom Faucet	22440602-001BF	10/20/23	ND	Non-Detect			
Classroom 7 Math Bathroom Faucet	22440602-002BF	10/20/23	ND	Non-Detect			
Classroom 8 Third Grade Bathroom Faucet	22440603-001BF	10/20/23	ND	Non-Detect			
Classroom 9 Fifth Grade Bathroom Faucet	22440603-002BF	10/20/23	ND	Non-Detect			
Classroom 10 Second Grade Bathroom Faucet	22440604-001BF	10/20/23	ND	Non-Detect			
Classroom 11 Fourth Grade Bathroom Faucet	22440604-002BF	10/20/23	ND	Non-Detect			